

CITY OF FORT WAYNE THOMAS C. HENRY, MAYOR NEIGHBORHOOD CODE COMPLIANCE

9/1/2021

Case #: 20-152MH-10413

List of Violations

Property Address for: **1915 E STATE BLVD**

152.04.D.2 - Exterior Structure. Protective treatment:

Violation: SCRAPE AND PAINT ALL PEELING/FLAKING/MISSING PAINT ON EXTERIOR SURFACES OF THE HOUS AND GARAGE;

REPAIR OR REPLACE LOOSE/DAMAGED SIDING ON THE HOUSE AND GARAGE

152.04.D.5 - Exterior Structure. Exterior walls:

Violation: REAR WALL OF THE GARAGE IS BOWING SIGNIFICANTLY

152.04.D.14 - Exterior Structure. Exterior Doors:

Violation: DOOR JAMBS ON THE HOUSE ENTRY AND GARAGE ENTRY DOORS NEED TO BE REPLACED; REPLACE MISSING OVERHEAD GARAGE DOOR; REAR ENTRY DOOR IS NOT INSTALLED PROPERLY

152.05.C - Interior Structure. Interior surfaces:

Violation: REPAIR AND PAINT DAMAGE/HOLES IN DRYWALL/PLASTER; REPLACE DAMAGED/MISSING INTERIOR TRIM COMPONENTS; REPLACE MISSING CABINET DOORS AND DRAWERS; REPLACE MISSING ATTIC ACCESS COVER

152.05.D.2 - Floors, stairs and walking surfaces:

Violation: REPAIR OR REPLACE DAMAGED AND OR MISSING FLOOR COVERINGS

152.05.E - Interior doors:

Violation: REPLACE MULTIPLE MISSING INTERIOR DOORS

152.05.G.1 - Kitchen and kitchen facilities:

Violation: THE STOVE AND REFRIGERATOR ARE MISSING

152.06.C.2 - Ventilation. Bathrooms and toilet rooms:

Violation: BATHROOM EXHAUST FAN IS NOT OPERABLE

152.06.C.3 - Ventilation. Clothes dryer exhaust:

Violation: THE DRYER VENT DOES NOT TERMINATE THE EXTERIOR WALL PROPERLY

152.07.D.1 - Water Systems. General:

Violation: KITCHEN FAUCET DRIPS CONSTANTLY

152.07.D.3 - Water Systems. Water heating facilities:

Violation: WATER HEATER IS NOT IN AN OPERABLE CONDITION AND THE FLUE PIPE IS MISSING

152.08.B.1 - Heating Facilities. Facilities required:

Violation: FURNACE IS NOT OPERABLE AND PARTIALLY DISMANTLED

152.08.E.1 - Electrical Equipment. Installation/Maintenance:

Violation: ELECTRICAL IS ONLY WORKING IN PARTS OF THE HOUSE; OPEN ELECTRICAL IN MULTIPLE AREAS OF THE HOUSE; THERE APPEARS TO BE ALUMINUM FOIL WRAPPED AROUND THE GFCI IN THE KITCHEN; REPLACE BURNT RECEPTACLE; REPLACE MISSING CEILING LIGHT FIXTURE IN BEDROOM; ALL CEILING LIGHTS NEED TO HAVE PROTECTIVE GLOBES INSTALLED; THERE IS OPEN ELECTRICAL IN MULTIPLE AREAS OF THE GARAGE

152.08.E.2.b - Electrical Equipment. Electrical Equipment. Receptacles:

Violation: KITCHEN GFCI DOES NOT WORK PROPERLY

152.09.B - Restrictions:

Violation: GAS SERVICE IS OFF AND THE METER HAS BEEN REMOVED

152.10.B.2 - Means of Egress. Exits:

Violation: BOTH ENTRY DOORS ARE BOARDED

152.10.C.2 - Fire Protection Systems. Smoke alarms:

Violation: THERE ARE NO WORKING SMOKE ALARMS

152.10.A.2.a - Safety and Sanitary Maintenance. General. Responsibility - Floors: Violation: REMOVE ANIMAL FECES

SAFE CITY * QUALITY JOBS * B.E.S.T.

Citizens Square * 200 E. Berry Street * Fort Wayne, Indiana * 46802 * www.cityoffortwayne.org An Equal Opportunity Employer



CITY OF FORT WAYNE THOMAS C. HENRY, MAYOR NEIGHBORHOOD CODE COMPLIANCE

9/1/2021

Case #: 20-RESCV-10412

List of Violations

Property Address for: **1915 E STATE BLVD**

This item is condemnable:

152.05.G.1 - Kitchen and kitchen facilities:

Violation: THE STOVE AND REFRIGERATOR ARE MISSING

This item is condemnable:

152.07.D.3 - Water Systems. Water heating facilities:

Violation: WATER HEATER IS NOT IN AN OPERABLE CONDITION AND THE FLUE PIPE IS MISSING

This item is condemnable:

152.08.B.1 - Heating Facilities. Facilities required:

Violation: FURNACE IS NOT OPERABLE AND PARTIALLY DISMANTLED

This item is condemnable:

152.08.E.1 - Electrical Equipment. Installation/Maintenance:

Violation: ELECTRICAL IS ONLY WORKING IN PARTS OF THE HOUSE; OPEN ELECTRICAL IN MULTIPLE AREAS OF THE HOUSE; THERE APPEARS TO BE ALUMINUM FOIL WRAPPED AROUND THE GFCI IN THE KITCHEN; REPLACE BURNT RECEPTACLE

This item is condemnable:

152.09.B - Restrictions:

Violation: GAS SERVICE IS OFF AND THE METER HAS BEEN REMOVED

This item is condemnable:

152.10.B.2 - Means of Egress. Exits:

Violation: BOTH ENTRY DOORS ARE BOARDED

This item is condemnable:

152.10.C.2 - Fire Protection Systems. Smoke alarms:

Violation: THERE ARE NO WORKING SMOKE ALARMS

SAFE CITY * QUALITY JOBS * B.E.S.T. Citizens Square * 200 E. Berry Street * Fort Wayne, Indiana * 46802 * www.cityoffortwayne.org An Equal Opportunity Employer